

4
Tele: 6060 (Mil)

Garrison Engineer Narangi
Satgaon-PO, Kamrup Dist
Guwahati- 781 027


2010/G/ 139/E2

24 Mar 2014

HQ Chief Engineer
Shillong Zone
PIN-900 332
C/o 99 APO

TRIAL OF M/S FIRESTONE RUBBER GUARD WATER PROOFING SYSTEM

1. Ref E-in-C's Branch letter No 43285/Prod-Misc/98/Des-2 dt 28 Feb 2014 addressed to HQ CE Shillong Zone with a copy to this office.
2. It is intimated that, EPDM membrane had been applied by M/s Delhi Builders Stores on 21 Jan 2008 over the roof of Qtr No B-208 in Phase-I under GE Narangi as trial basis.
3. The Qtr has been checked and no leakage/seepage is found from the Qtr since EPDM membrane applied on roof of Qtr No B-208 by M/s Delhi Builders Stores.
4. Hence the performance of the material may be considered as satisfactory.


(Vivek Jain)
EE
Garrison Engineer

Copy to:-

HQ CWE Shillong
Spred Eagle Falls
Shillong - 793 011

- for info please.

M/s Delhi Builders Stores
8253-54 Shradhdharand Marg
Delhi - 110 006

- with reference to your letter DBS/13-14/NKK/
MES/Shillong Zone dated 08 Mar 2014.